

Appendix G  
Excel Template for Lead Results

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certifica tion ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
2	#1 WC #1	N	8944253	Eurofins Lancaster Labs	PA011	04/14/2017	08:07	200.8	04/24/2017	06:43	<1.0	1.0	1	N	ND
3	#2 WC #2	N	8944254	Eurofins Lancaster Labs	PA011	04/14/2017	08:08	200.8	04/24/2017	06:44	2.2	1.0	1	N	
4	#3 TL-S1	N	8944255	Eurofins Lancaster Labs	PA011	04/14/2017	08:11	200.8	04/24/2017	06:45	1.4	1.0	1	N	
5	#4 TL-S2	N	8944256	Eurofins Lancaster Labs	PA011	04/14/2017	08:11	200.8	04/24/2017	06:46	<1.0	1.0	1	N	ND
6	#5 TL-S3	N	8944257	Eurofins Lancaster Labs	PA011	04/14/2017	08:12	200.8	04/24/2017	06:48	1.2	1.0	1	N	
7	#6 WC #3	N	8944258	Eurofins Lancaster Labs	PA011	04/14/2017	08:13	200.8	04/24/2017	06:49	1.2	1.0	1	N	
8	#7 WC #4	N	8944259	Eurofins Lancaster Labs	PA011	04/14/2017	08:14	200.8	04/24/2017	06:52	<1.0	1.0	1	N	ND
9	#8 WC #5	N	8944260	Eurofins Lancaster Labs	PA011	04/14/2017	08:15	200.8	04/24/2017	06:54	1.9	1.0	1	N	
10	#9 WC #6	N	8944261	Eurofins Lancaster Labs	PA011	04/14/2017	08:15	200.8	04/24/2017	07:40	<1.0	1.0	1	N	ND
11	#10 BRS-110-1	N	8944262	Eurofins Lancaster Labs	PA011	04/14/2017	08:17	200.8	04/24/2017	07:48	3.7	1.0	1	N	
12	#11 BRS-110-2	N	8944263	Eurofins Lancaster Labs	PA011	04/14/2017	08:17	200.8	04/24/2017	07:49	4.3	1.0	1	N	
13	#12 BRS-110-3	N	8944264	Eurofins Lancaster Labs	PA011	04/14/2017	08:18	200.8	04/24/2017	07:50	5.7	1.0	1	N	
14	#13 GRS-110-1	N	8944265	Eurofins Lancaster Labs	PA011	04/14/2017	08:20	200.8	04/24/2017	07:51	5.2	1.0	1	N	
15	#14 GRS-110-2	N	8944266	Eurofins Lancaster Labs	PA011	04/14/2017	08:21	200.8	04/24/2017	07:52	2.1	1.0	1	N	
16	#15 GRS-110-3	N	8944267	Eurofins Lancaster Labs	PA011	04/14/2017	08:21	200.8	04/24/2017	07:54	2.5	1.0	1	N	
17	#16 NS-115	N	8944268	Eurofins Lancaster Labs	PA011	04/14/2017	08:22	200.8	04/24/2017	07:55	2.3	1.0	1	N	
18	#17 DW-107	N	8944269	Eurofins Lancaster Labs	PA011	04/14/2017	08:24	200.8	04/24/2017	07:58	1.2	1.0	1	N	
19	#18 DW-105	N	8944270	Eurofins Lancaster Labs	PA011	04/14/2017	08:25	200.8	04/24/2017	07:59	3.6	1.0	1	N	
20	#19 DW-104	N	8944271	Eurofins Lancaster Labs	PA011	04/14/2017	08:29	200.8	04/24/2017	08:23	<1.0	1.0	1	N	ND
21	#20 SK-104	N	8944272	Eurofins Lancaster Labs	PA011	04/14/2017	08:29	200.8	04/24/2017	08:29	1.4	1.0	1	N	
22	#21 DW-102	N	8944273	Eurofins Lancaster Labs	PA011	04/14/2017	08:30	200.8	04/24/2017	08:30	2.0	1.0	1	N	
23	#22 DW-101	N	8944274	Eurofins Lancaster Labs	PA011	04/14/2017	08:32	200.8	04/24/2017	08:31	4.6	1.0	1	N	
24	#23 WC #7	N	8944275	Eurofins Lancaster Labs	PA011	04/14/2017	08:33	200.8	04/24/2017	08:34	1.4	1.0	1	N	
25	#24 WC #8	N	8944276	Eurofins Lancaster Labs	PA011	04/14/2017	08:35	200.8	04/24/2017	08:36	<1.0	1.0	1	N	ND
26	#25 SK-103	N	8944277	Eurofins Lancaster Labs	PA011	04/14/2017	08:36	200.8	04/24/2017	08:37	2.6	1.0	1	N	
27	#26 HB #1	N	8944278	Eurofins Lancaster Labs	PA011	04/14/2017	08:37	200.8	04/24/2017	08:38	23.0	1.0	1	N	
28	#27 DW-103	N	8944279	Eurofins Lancaster Labs	PA011	04/14/2017	08:37	200.8	04/24/2017	08:39	5.4	1.0	1	N	
29	#28 SK-121-1	N	8944280	Eurofins Lancaster Labs	PA011	04/14/2017	08:42	200.8	04/24/2017	08:40	1.6	1.0	1	N	
30	#29 SK-121-2	N	8944281	Eurofins Lancaster Labs	PA011	04/14/2017	08:43	200.8	04/24/2017	09:28	16.9	1.0	1	N	
31	#30 SK-121-3	N	8944282	Eurofins Lancaster Labs	PA011	04/14/2017	08:43	200.8	04/24/2017	09:34	34.5	1.0	1	N	
32	#31 SK-127-1	N	8944283	Eurofins Lancaster Labs	PA011	04/14/2017	08:46	200.8	04/24/2017	09:35	<1.0	1.0	1	N	ND
33	#32 SK-127-2	N	8944284	Eurofins Lancaster Labs	PA011	04/14/2017	08:46	200.8	04/24/2017	09:36	<1.0	1.0	1	N	ND
34	#33 SK-127-3	N	8944285	Eurofins Lancaster Labs	PA011	04/14/2017	08:47	200.8	04/24/2017	09:39	<1.0	1.0	1	N	ND
35	#34 SK-127-4	N	8944286	Eurofins Lancaster Labs	PA011	04/14/2017	08:48	200.8	04/24/2017	09:41	1.5	1.0	1	N	
36	#35 SK-127-5	N	8944287	Eurofins Lancaster Labs	PA011	04/14/2017	08:49	200.8	04/24/2017	09:42	1.8	1.0	1	N	
37	#36 SK-127-6	N	8944288	Eurofins Lancaster Labs	PA011	04/14/2017	08:50	200.8	04/24/2017	09:43	1.4	1.0	1	N	
38	#38 SK-127-8	N	8944289	Eurofins Lancaster Labs	PA011	04/14/2017	08:51	200.8	04/24/2017	09:44	3.8	1.0	1	N	
39	#39 SK-129	N	8944290	Eurofins Lancaster Labs	PA011	04/14/2017	08:53	200.8	04/24/2017	09:45	2.0	1.0	1	N	

Appendix G  
Excel Template for Lead Results

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certifica tion ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
40	#40 SK-131-1	N	8944291	Eurofins Lancaster Labs	PA011	04/14/2017	08:54	200.8	04/24/2017	07:21	1.6	1.0	1	N	
41	#42 WC #9	N	8944292	Eurofins Lancaster Labs	PA011	04/14/2017	08:55	200.8	04/24/2017	07:33	<1.0	1.0	1	N	ND
42	#43 WC #10	N	8944293	Eurofins Lancaster Labs	PA011	04/14/2017	08:56	200.8	04/24/2017	07:35	<1.0	1.0	1	N	ND
43	#44 BRS-133-1	N	8944294	Eurofins Lancaster Labs	PA011	04/14/2017	08:57	200.8	04/24/2017	07:36	1.2	1.0	1	N	
44	#45 BRS-133-2	N	8944295	Eurofins Lancaster Labs	PA011	04/14/2017	08:58	200.8	04/24/2017	07:38	1.3	1.0	1	N	
45	#46 BRS-133-3	N	8944296	Eurofins Lancaster Labs	PA011	04/14/2017	08:59	200.8	04/24/2017	07:40	1.6	1.0	1	N	
46	#47 BRS-133-4	N	8944297	Eurofins Lancaster Labs	PA011	04/14/2017	08:59	200.8	04/24/2017	07:42	1.6	1.0	1	N	
47	#48 BRS-133-5	N	8944298	Eurofins Lancaster Labs	PA011	04/14/2017	09:04	200.8	04/24/2017	07:43	23.9	1.0	1	N	
48	#49 GRS-133-1	N	8944299	Eurofins Lancaster Labs	PA011	04/14/2017	09:06	200.8	04/24/2017	07:45	20.7	1.0	1	N	
49	#50 GRS-133-2	N	8944300	Eurofins Lancaster Labs	PA011	04/14/2017	09:07	200.8	04/24/2017	07:50	1.4	1.0	1	N	
50	#51 GRS-133-3	N	8944301	Eurofins Lancaster Labs	PA011	04/14/2017	09:07	200.8	04/24/2017	08:44	<1.0	1.0	1	N	ND
51	#52 GRS-133-4	N	8944302	Eurofins Lancaster Labs	PA011	04/14/2017	09:08	200.8	04/24/2017	08:52	1.1	1.0	1	N	
52	#53 GRS-133-5	N	8944303	Eurofins Lancaster Labs	PA011	04/14/2017	09:09	200.8	04/24/2017	08:53	1.4	1.0	1	N	
53	#54 SK-201-1	N	8944304	Eurofins Lancaster Labs	PA011	04/14/2017	09:12	200.8	04/24/2017	08:54	3.1	1.0	1	N	
54	#55 SK-201-2	N	8944305	Eurofins Lancaster Labs	PA011	04/14/2017	09:13	200.8	04/24/2017	08:55	1.1	1.0	1	N	
55	#56 WC #11	N	8944306	Eurofins Lancaster Labs	PA011	04/14/2017	09:14	200.8	04/24/2017	08:57	<1.0	1.0	1	N	ND
56	#57 WC #12	N	8944307	Eurofins Lancaster Labs	PA011	04/14/2017	09:15	200.8	04/24/2017	08:58	<1.0	1.0	1	N	ND
57	#59 BRS-213-2	N	8944308	Eurofins Lancaster Labs	PA011	04/14/2017	09:16	200.8	04/24/2017	08:59	7.5	1.0	1	N	
58	#60 BRS-213-3	N	8944309	Eurofins Lancaster Labs	PA011	04/14/2017	09:17	200.8	04/24/2017	09:02	<1.0	1.0	1	N	ND
59	#61 BRS-213-4	N	8944310	Eurofins Lancaster Labs	PA011	04/14/2017	09:18	200.8	04/24/2017	09:04	<1.0	1.0	1	N	ND
60	#62 GRS-213-1	N	8944311	Eurofins Lancaster Labs	PA011	04/14/2017	09:22	200.8	04/21/2017	06:31	1.0	1.0	1	N	
61	#63 GRS-213-2	N	8944312	Eurofins Lancaster Labs	PA011	04/14/2017	09:23	200.8	04/21/2017	06:47	<1.0	1.0	1	N	ND
62	#64 GRS-213-3	N	8944313	Eurofins Lancaster Labs	PA011	04/14/2017	09:24	200.8	04/21/2017	06:48	1.1	1.0	1	N	
63	#65 GRS-213-4	N	8944314	Eurofins Lancaster Labs	PA011	04/14/2017	09:24	200.8	04/24/2017	11:02	1.2	1.0	1	N	
64	#66 SK-217	N	8944315	Eurofins Lancaster Labs	PA011	04/14/2017	09:26	200.8	04/24/2017	11:10	2.5	1.0	1	N	
65	#67 WC #13	N	8944316	Eurofins Lancaster Labs	PA011	04/14/2017	09:27	200.8	04/24/2017	11:12	<1.0	1.0	1	N	ND
66	#68 WC #14	N	8944317	Eurofins Lancaster Labs	PA011	04/14/2017	09:28	200.8	04/24/2017	11:14	<1.0	1.0	1	N	ND
67	#69 SK-226	N	8944318	Eurofins Lancaster Labs	PA011	04/14/2017	09:30	200.8	04/24/2017	11:19	2.3	1.0	1	N	
68	#70 SK-224	N	8944319	Eurofins Lancaster Labs	PA011	04/14/2017	09:30	200.8	04/24/2017	11:20	1.1	1.0	1	N	
69	#71 SK-216	N	8944320	Eurofins Lancaster Labs	PA011	04/14/2017	09:33	200.8	04/24/2017	11:22	1.1	1.0	1	N	
70	#72 KC-DW	N	8944321	Eurofins Lancaster Labs	PA011	04/14/2017	09:37	200.8	04/24/2017	11:24	<1.0	1.0	1	N	ND
71	#73 KC-HW	N	8944322	Eurofins Lancaster Labs	PA011	04/14/2017	09:37	200.8	04/24/2017	11:26	2.2	1.0	1	N	
72	#74 FP	N	8944323	Eurofins Lancaster Labs	PA011	04/14/2017	09:38	200.8	04/24/2017	11:27	4.8	1.0	1	N	
73	#75 KS	N	8944324	Eurofins Lancaster Labs	PA011	04/14/2017	09:39	200.8	04/24/2017	11:32	1.9	1.0	1	N	
74	#76 KC-1	N	8944325	Eurofins Lancaster Labs	PA011	04/14/2017	09:41	200.8	04/24/2017	11:44	7.5	1.0	1	N	
75	#77 KC-2	N	8944326	Eurofins Lancaster Labs	PA011	04/14/2017	09:41	200.8	04/24/2017	11:46	10.3	1.0	1	N	
76	#78 KC-3	N	8944327	Eurofins Lancaster Labs	PA011	04/14/2017	09:42	200.8	04/24/2017	11:48	49.1	1.0	1	N	
77	#83 HB #7	N	8944328	Eurofins Lancaster Labs	PA011	04/14/2017	09:47	200.8	04/24/2017	11:49	38.8	1.0	1	N	

Appendix G  
Excel Template for Lead Results

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certifica tion ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
78	#84 HB #8	N	8944329	Eurofins Lancaster Labs	PA011	04/14/2017	09:50	200.8	04/24/2017	11:51	74.4	1.0	1	N	
79	#85 HB #9	N	8944330	Eurofins Lancaster Labs	PA011	04/14/2017	09:51	200.8	04/24/2017	11:53	4.4	1.0	1	N	
80	#86 HB #10	N	8944331	Eurofins Lancaster Labs	PA011	04/14/2017	09:53	200.8	04/24/2017	11:54	18.6	1.0	1	N	
81	#58 BRS-213-1	N	8944332	Eurofins Lancaster Labs	PA011	04/14/2017	09:19	200.8	04/24/2017	12:00	5.9	1.0	1	N	
82	Field Blank	N	8944333	Eurofins Lancaster Labs	PA011	04/17/2017	16:19	200.8	04/24/2017	12:01	<1.0	1.0	1	N	ND